

Pre-Application Site Visit Report

Project 6440514, 1981 NE COLUMBIA RD

Assessment Completed: 10/16/2014

Project Description: INTERIOR ALTERATION OF ROOM 132 IN THE CENTER ON HUMAN DEVELOPMENT AND DISABILITY SCHOOL AT UW. WO#314042

Primary Applicant: [Lauren Eck](#)

This report lists a preliminary assessment of project requirements based on your pre-application site visit (PASV). The PASV is completed by site inspectors from the Department of Planning and Development (DPD).

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact:
Kathleen H Wilson, (206) 233-7932, Kathleen.Wilson@seattle.gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:
Peat

Earth Disturbance

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Existing trees appear to be shown accurately on the site plan

Inspectors Notes

This project involves interior work only. Geocortex mapping is for the entire UW site. The only mapped ECAs for this portion of UW property are Peat Settlement and Shoreline Habitat. See Tip (CAM) 327B for possible ECA submittal requirement exemptions.

Standard Submittal Requirements for Projects in an ECA

Site is mapped as a peat settlement-prone areas; see SMC [25.09.110](#) and [Tip 325](#)

For construction activity requiring more than 30 inches of excavation, a geotechnical report meeting the standards of [Director's Rule 13-2008](#) is required to determine the annual high-static groundwater level. No development is allowed below the annual high-static groundwater level except as allowed in SMC [25.09.110](#)